

2021 WATER QUALITY REPORT FOR THORNTON WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	6.00 (1 - 10)	2020	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.09 (0.01 - 0.15)	2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	0.8 (0.5 - 1.2)	12/31/2021	No	Water additive used to control microbes
01 - S/EP FOR WELL # 1 (1955) AFTER TREATMENT						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	2.4	04/25/2021	No	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	SGL	2.7	07/07/2020	No	Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	2.066	08/04/2020	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	22	08/06/2019	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	0.4800	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
02 - S/EP FOR WELL # 2 (1988) AFTER TREATMENT						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	2.3	04/25/2021	No	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	SGL	4.3	07/07/2020	No	Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	2.076	08/04/2020	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	25	08/06/2019	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	0.6800	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.